

1. Following changes are made in the accounting due to non availability/Discrepancies of Main Meter readings.

Sl.no	Date	Location	Feeder/ICT	Loc.ID& SEM Sl.no	Repalced with LOC.ID& SEM Sl.no	Remarks
1	03.01.14 TO 09.02.14	Anuppur	200kv Kotmikala line 1	(MP-56) NP-2163-A	(CS-51) NP-2413-A	Data was corrupted.Less energy recorded.
2	03.01.14 TO 09.02.14	Bhilai	400KV Korba-line-1	(CS-89) NP-2893-A	(KO-21) NP-2250-A	Only 1/3 rd energy recorded by SEM at Bhilai
3	03.01.14 TO 09.02.14	Balaghat	132kV Dongargarh line	(MP-85) NP-2156-A	(CS-82) NP-2349-A	Data not received.
4	03.01.14 TO 09.02.14	Aurangabad(MS EB)	400KV Akola line-1	(MH-49) NP-6264-A	(MH-47) NP-6269-A	Data not received.
5	03.01.14 TO 09.02.14	Aurangabad(MS EB)	400KV Akola line-1	(MH-50) NP-6265-A	(MH-48) NP-6270-A	Data not received.
6	03.01.14 TO 09.02.14	Wardha	400KV Akola line-2	(MH-45) NP-6273-A	(MH-46) NP-6268-A	Data not received.