

1. Following changes are made in the accounting due to non availability/Discrepancies of Main Meter readings.

Sl. no	Date	Location	Feeder/ICT	Loc.ID& SEM Sl.no	Repalced with LOC.ID& SEM Sl.no	Remarks
1	03.03.14 TO 09.03.14	Anuppur	200kv Kotmikala line 1	(MP-56) NP-2163-A	(CS-51) NP-2413-A	Data was corrupted.Less energy recorded.
2	03.03.14 TO 09.03.14	Balaghat	132kV Dongargarh line	(MP-85) NP-2156-A	(CS-82) NP-2349-A	Data not received.
3	03.03.14 TO 09.03.14	Solapur(PG)	400KV Parli line-2	(MH-77) NP-6743-A	(MH-79) NP-6742-A	Data not received.