

Actual Active and Reactive energy Accounting for the week 04.07.16 to 10.07.16

I.Active Energy Accounting

1. Following changes are made in the accounting due to non availability/Discrepancies of Main Meter readings.

Sl.no	Date	Location	Feeder/ICT	Loc.ID& SEM Sl.no	Repalced with LOC.ID& SEM Sl.no	Remarks
1	04.06.16 To 10.07.16	RGPPPL	400kV Nagothane line-2	(RG-22) NP-6324-A	(RG-26) NP-6297-A	Time drift issue
2	04.06.16 To 10.07.16	Haldarwa	220kV KAPS-2	(GU-54) NP-4161-A	(KA-22) NP-2343-A	Data was corrupt
3	04.06.16 To 10.07.16	Aurangabad (MSEB)	400kV Aurangabad(PG) Line-2	MH-50 NP-6265-A	MM-56 NP- 8747-A	Meter was replaced
4	30.06.16 To 03.07.16	Kolhapur (MSEB)	400KV Solapur(PG) line-1	MM-29 NP- 6712-A	MM-26 NP- 2650-A	Data was not received
5	03.07.16	Satpura	400kV Seoni line	(MP-38) NP-2335-A	(MP-50) NP-5745-A	Data was corrupt