

1. Following changes are made in the accounting due to non availability/Discrepancies of Main Meter readings.

Sl.no	Date	Location	Feeder/ICT	Loc.ID& SEM Sl.no	Repalced LOC.ID& Sl.no	with SEM	Remarks
1	07.01.13 To 13.01.13	Indore	400KV Bina(PG) line	(MB-30) NP-2601-A	(MB-31) NP5760-A		Data was corrupted.
2	07.01.13 To 13.01.13	Sugen	400kV Gandhar line-1	(SU-11) GJ-2292-A	(GA-26) NP-2340-A		Less recording of energy at Sugan end.
3	07.01.13 To 13.01.13	Chandrapur	400kV Bhadravati line-4	(MH-39) NP-2322-A	(MH-41) NP-2321-A		Data not received, line not in service.
4	07.01.13 To 13.01.13	Ichhapur	220kV Kawas line-2	(GG-62) NP-2604-A	(KW-14) NP-2602-A		Data not received
5	07.01.13 To 13.01.13	Wardha	400kV Parli line- 2	(MH-81) NP-6726-A	(MH-60) NP-6718-A		Data not received
6	07.01.13 To 13.01.13	Wardha	400kV Raipur line-2	(MM-21) NP-6724-A	(CS-78) NP-2824-A		Data not received
7	07.01.13 To 13.01.13	IEPL	400kV Wardha line	(IE-12) NP-2386-A	(MD-21) NP-2637-A		Line not in service for the whole week
8	07.01.13 To 13.01.13	RGPPPL	400kV Nagothane line 2	(RG-22) NP-6327-A	(RG-26) NP-6297-A		Erronious data recorded by SEM