

Actual Active and Reactive energy Accounting for the week 09.05.16 to 15.05.16

I.Active Energy Accounting

1. Following changes are made in the accounting due to non availability/Discrepancies of Main Meter readings.

Sl.no	Date	Location	Feeder/ICT	Loc.ID& SEM Sl.no	Repalced with LOC.ID& SEM Sl.no	Remarks
1	09.05.16 To 15.05.16	RGPPPL	400kV Nagothane line-2	(RG-22) NP-6324-A	(RG-26) NP-6297-A	Time drift issue
2	09.05.16 To 15.05.16	Haldarwa	220kV KAPS-2	(GU-54) NP-4161-A	(KA-22) NP-2343-A	Data was corrupt
3	09.05.16 To 15.05.16	Balghat	132kV Dongargarh line	(MP-85) NP-2156-A	(CS-82) NP-2349-A	Data was not received
4	10.05.16	Jharsuguda	765kV Dharamjaygarh line-2	(WR-74) NP-7638-A	(WR-72) NP-8780-A	Data was corrupt
5	09.05.16	Raipur	400kV side of ICT-2	(CS-03) NP-2327-A	(CS-04) NP-2143-A	Data was corrupt