

## ANNEXURE

**Actual Active and Reactive energy Accounting for the week 11.04.16 to 17.04.16****I.Active Energy Accounting****1. Following changes are made in the accounting due to non availability/Discrepancies of Main Meter readings.**

Sl.no	Date	Location	Feeder/ICT	Loc.ID& SEM Sl.no	Repalced with LOC.ID& SEM Sl.no	Remarks
1	11.04.16	AURANGABAD (PG)	400KV SIDE OF ICT-2	(MM-49) NP-8716-A	(MM-50) NP-8715-A	Data was corrupt
2	16.04.16 & 17.04.16	Kolhapur(GIS)	400KV Kudgi line-2	PG-77 NP- 8843-A	PG-79 NP- 9614-A	Data was not received
3	13.04.16 & 16.04.16	TAMNAR(PS)	400KV JPL STG-2 LINE-4	WR-62NP- 8689-A	JD-21 NP- 2876-A	Data was corrupt
4	16.04.16	Solapur(PG)	400KV Parli(PG) line-1	MH-76NP- 6744-A	MH-78NP- 6742-A	SEM was calibrated