

Actual Active and Reactive energy Accounting for the week 13.06.16 to 19.06.16**I.Active Energy Accounting****1. Following changes are made in the accounting due to non availability/Discrepancies of Main Meter readings.**

Sl.no	Date	Location	Feeder/ICT	Loc.ID& SEM Sl.no	Repalced with LOC.ID& SEM Sl.no	Remarks
1	13.06.16 To 19.06.16	RGPPPL	400kV Nagothane line-2	(RG-22) NP-6324-A	(RG-26) NP-6297-A	Time drift issue
2	13.06.16 To 19.06.16	Haldarwa	220kV KAPS-2	(GU-54) NP-4161-A	(KA-22) NP-2343-A	Data was corrupt
3	16.06.16	Nasik	220kV Navsari line-1	(MH-54) NP-2345-A	(GU-61) NP-4171-A	SEM calibration was done
4	15.06.16	Nasik	220kV Navsari line-2	(MH-55) NP-2199-A	(GU-62) NP-4172-A	SEM calibration was done
5	17.06.16	Dhule	400kV Khandwa line-1	(MH-25) NP-2152-A	(MP-41) NP-2142-A	SEM calibration was done
6	17.06.16	Dhule	400kV Khandwa line-2	(MH-26) NP-2182-A	(MP-42) NP-2107-A	SEM calibration was done
7	18.06.16 & 19.06.16	Birsingpur	400KV Vandana line	(MB-24) NP-6833-A	(VV-13) NP-2655-A	Data was corrupt
8	14.06.16	Parli(MSEB)	400KV Parli(PG) line-1	(MH-66) NP-6723-A	(MH-63) NP-6720-A	Data was corrupt