

ANNEXURE

Actual Active and Reactive energy Accounting for the week 14.03.16 to 20.03.16**I.Active Energy Accounting****1. Following changes are made in the accounting due to non availability/Discrepancies of Main Meter readings.**

Sl.no	Date	Location	Feeder/ICT	Loc.ID& SEM Sl.no	Repalced with LOC.ID& SEM Sl.no	Remarks
1	14.03.16 To 20.03.16	Khadoli	220kV SAYALI line	(DN-87) NP-2925-A	(DN-80) NP-6412-A	Data was corrupt
2	14.03.16 To 20.03.16	RGPPL	400kV Nagothane line-2	(RG-22) NP-6327-A	(RG-26) NP-6297-A	Data was corrupt
3	14.03.16 & 19.03.16	KALA(PG)	220KV SIDE OF ICT-1	(GG-77) NP-2994-A	(GG-76) NP-2990-A	Data was corrupt
4	14.03.16 To 20.03.16	Limbdi	400KV CGPL line-1	(GG-54) NP-6345-A	(CG-29) CG-1001-A	Data was not received
5	14.03.16 To 20.03.16	Limbdi	400KV Mansar line	(GG-55) NP-6428-A	(GR-16) NP-2777-A	Data was not received
6	18.03.16	Seoni(PG)	400kV side of 400/220kV ICT-1	(MP-19) NP-5741-A	(MP-20) NP-5736-A	Calibration was done
7	18.03.16	ITARSI(PG)	400kV side of 400/220kV ICT-1	(IT-01) NP-4224-A	(IT-02) NP-2475-A	Data was corrupt
8	14.03.16	Akola	400kV Wardha line-2	(MH-46) NP-6268-A	(MH-45) NP-6758-A	Calibration was done
9	17.03.16	Wardha(PG)	400KV Side of ICT-1	(MM-12) NP-6770-A	(MM-11) NP-6769-A	Data was corrupt
10	17.03.16	Wardha(PG)	400KV Side of ICT-2	(MM-17) NP-6730-A	(MM-16) NP-6254-A	Data was corrupt

11	17.03.16	Wardha(PG)	400KV Side of ICT-3	(MM-19) NP-6773-A	(MM-18) NP-6772-A	Data was corrupt
12	14.03.16	Budhipadar	220kV Korba line-3	(OR-58) NP-5944-A	(CS-55) NP-2133-A	Data was corrupt