

Actual Active and Reactive energy Accounting for the week 18.04.16 to 24.04.16

I.Active Energy Accounting

I. Following changes are made in the accounting due to non availability/Discrepancies of Main Meter readings.

Sl.no	Date	Location	Feeder/ICT	Loc.ID& SEM Sl.no	Repalced with LOC.ID& SEM Sl.no	Remarks
1	18.04.16 20.04.16 & 23.04.16	TAMNAR(PS)	400KV JPL STG-2 LINE-4	(WR-62) NP-8689-A	(JD-21) NP-2876-A	Data was corrupt
2	18.04.16 & 24.04.16	RGPPL	400kV Nagothane line-2	(RG-22) NP-6324-A	(RG-26) NP-6297-A	Time drift issue
3	18.04.16 & 24.04.16	Haldarwa	220kV KAPS-2	(GU-54) NP-4161-A	(KA-22) NP-2343-A	Data was corrupt