

Actual Active and Reactive energy Accounting for the week 20.06.16 to 26.06.16

I.Active Energy Accounting

1. Following changes are made in the accounting due to non availability/Discrepancies of Main Meter readings.

Sl.no	Date	Location	Feeder/ICT	Loc.ID& SEM Sl.no	Repalced with LOC.ID& SEM Sl.no	Remarks
1	13.06.16 To 19.06.16	RGPPPL	400kV Nagothane line-2	(RG-22) NP-6324-A	(RG-26) NP-6297-A	Time drift issue
2	13.06.16 To 19.06.16	Haldarwa	220kV KAPS-2	(GU-54) NP-4161-A	(KA-22) NP-2343-A	Data was corrupt
3	23.06.16 & 24.06.16	Birsingpur	400KV Vandana line	(MB-24) NP-6833-A	(VV-13) NP-2655-A	Data was corrupt
4	21.06.16	Gwalior(PG)	765KV Jaipur(Phagi_NR) line 1	(PG-48) NP-5755-A	(PG-50) NP-8274-A	Data was corrupt
5	20.06.16	Aurangabad (MSEB)	400kV Aurangabad(PG) Line-1	(MH-49) NP-6264-A	(MM-55) NP-8743-A	SEM calidration was done
6	21.06.16	Aurangabad (MSEB)	400kV Aurangabad(PG) Line-2	(MH-50) NP-6265-A	(MM-56) NP-8747-A	SEM calidration was done