

ANNEXURE

Actual Active and Reactive energy Accounting for the week 22.09.14 to 28.09.14**I.Active Energy Accounting**

1. Following changes are made in the accounting due to non availability/Discrepancies of Main Meter readings.

| Sl.no | Date | Location | Feeder/ICT | Loc.ID& SEM Sl.no | Repalced with LOC.ID& SEM Sl.no | Remarks |
|--------------|----------------------------|-----------------|---------------------------------------|----------------------------------|--|--|
| 1 | 22.09.14 to 28.09.14 | Anuppur | 200kv Kotmikala line 1 | (MP-56) NP-2163-A | (CS-51) NP-2413-A | Data was corrupt |
| 2 | 22.09.14 to 28.09.14 | Bhadravati | 400kV Line-1 to HVDC at Bhadravati | (WR-31) NP-4165-A | (WR-33) NP-2310-A | Data was corrupt |
| 3 | 22.09.14 to 28.09.14 | Bhadravati | 400kV Line-2 to HVDC at Bhadravati | (WR-32) NP-4214-A | (WR-34) NP-4215-A | Data was corrupt |
| 4 | 22.09.14 to 28.09.14 | SEONI | 400kv side of ICT 2 at Seoni | (MP-58) NP-5743-A | (MP-59) NP-5738-A | Meter recording 2/3 rd energy. |
| 5 | 22.09.14 to 28.09.14 | Kolapur | 400kv Solapur line-1 | (MM-29) NP-6712-A | (MM-26) NP-2650-A | Data not received |
| 6 | 22.09.14 to 28.09.14 | Kolapur | 400kv Solapur line-2 | (MM-28) NP-6712-A | (MM-27) NP-2650-A | Data not received |