

**1. Following changes are made in the accounting due to non availability/Discrepancies of Main Meter readings.**

Sl.no	Date	Location	Feeder/ICT	Loc.ID& SEM Sl.no	Repalced with LOC.ID& SEM Sl.no	Remarks
1	25.04.16 To 01.05.16	RGPPL	400kV Nagothane line-2	(RG-22) NP-6324-A	(RG-26) NP-6297-A	Time drift issue
2	25.04.16 To 01.05.16	Haldarwa	220kV KAPS-2	(GU-54) NP-4161-A	(KA-22) NP-2343-A	Data was corrupt
3	25.04.16 To 01.05.16	CGPL	400KV Mansar line	(CG-31) CG-1004-A	(CG-32) CG-1003-A	Data was not received
4	25.04.16 To 01.05.16	Bhadravati (west bus)	400kV Line-1 to HVDC	(WR-31) NP-4165-A	(WR-33) NP-2310-A	Data was corrupt
5	25.04.16 To 01.05.16	Bhadravati (west bus)	400kV Line-2 to HVDC	(WR-32) NP-4214-A	(WR-34) NP-4215-A	Data was corrupt