

1. Following changes are made in the accounting due to non availability/Discrepancies of Main Meter readings.

Sl.no	Date	Location	Feeder/ICT	Loc.ID& SEM Sl.no	Repalced with LOC.ID& SEM Sl.no	Remarks
1	27.01.14 TO 02.02.14	Ujjain	220kV Kota line	(MP-54) NP-2138-A	(RS-01) NP-1067-B	Due to DCD problem, data not received.
2	27.01.14 TO 02.02.14	Ujjain	220kV Motak line	(MP-55) NP-2148-A	(RS-03) NP-1301-A	Due to DCD problem, data not received.
3	27.01.14 TO 02.02.14	Anuppur	200kv Kotmikala line 1	(MP-56) NP-2163-A	(CS-51) NP-2413-A	Data was corrupted.
4	27.01.14 TO 02.02.14	Kolhapur	400KV Solapur(PG) line-2	(MM-28) NP-6713-A	(MM-27) NP-2651-A	Data not received.
5	27.01.14 TO 02.02.14	Korba(NTPC)	400KV BHILAI LINE-II	(KO-12) NP-2176-A	(KO-22) NP-2249-A	Data was corrupted.
6	27.01.14 TO 02.02.14	Bhilai	400KV Korba-line-1	(CS-89) NP-2893-A	(KO-21) NP-2250-A	Only 1/3 rd energy recorded by SEM at Bhilai
7	27.01.14 TO 02.02.14	RGPPL	400kV Nagothane line-2	(RG-22) NP-6327-A	(RG-26) NP-6297-A	Data not received.
8	27.01.14 TO 02.02.14	Wardha	400KV Raipur line-2	(MM-21) NP-6724-A	(CS-78) NP-2824-A	Data not received.
9	27.01.14 TO 02.02.14	Balaghat	132kV Dongargarh line	(MP-85) NP-2156-A	(CS-82) NP-2349-A	Data not received.
10	27.01.14 TO 02.02.14	Jabalpur	400kV side of ICT-1	(MP-01) NP-2409-A	(MP-02) NP-2450-A	400KV side SEMs Less energy recorded

11	27.01.14 TO 02.02.14	Aurangabad(PG)	400KV PUNE LINE-1	(MM-38) NP-8700-A	(MM-36) NP-2881-A	Data not received.
12	27.01.14	TAMNAR(PS)	400KV JPL STG-2 LINE-4	(WR-62) NP-8689-A	(JD-21) NP-2876-A	Data not received.