

**Actual Active and Reactive energy Accounting for the week 29.09.14 to 05.10.14**

**I.Active Energy Accounting**

**1. Following changes are made in the accounting due to non availability/Discrepancies of Main Meter readings.**

| <b>Sl.no</b> | <b>Date</b>                | <b>Location</b> | <b>Feeder/ICT</b>            | <b>Loc.ID&amp;<br/>SEM Sl.no</b> | <b>Repalced<br/>with<br/>LOC.ID&amp;<br/>SEM Sl.no</b> | <b>Remarks</b>                            |
|--------------|----------------------------|-----------------|------------------------------|----------------------------------|--|---|
| 1            | 29.09.14<br>to<br>05.10.14 | Anuppur         | 200kv Kotmikala line 1       | (MP-56)<br>NP-2163-A             | (CS-51)<br>NP-2413-A                                   | Data was corrupt                          |
| 2            | 29.09.14<br>to<br>05.10.14 | SEONI           | 400kv side of ICT 2 at Seoni | (MP-58)<br>NP-5743-A             | (MP-59)<br>NP-5738-A                                   | Meter recording 2/3 <sup>rd</sup> energy. |
| 3            | 29.09.14<br>to<br>05.10.14 | RGPPPL          | 400kV Nagothane line-2       | (RG-22)<br>NP-6327-A             | (RG-26)<br>NP-6297-A                                   | Data not received                         |
| 4            | 03.10.14<br>to<br>05.10.14 | Budhipadar      | 200kv korba line-III         | (OR-58)<br>NP-5944-A             | (CS-55)<br>NP-2133-A                                   | Data was corrupt                          |