

पुस्तिका संख्या : 75
Book No. :

अनुक्रमांक :
Sr. No. 7415

पावर सिस्टम ऑपरेशन कारपोरेशन लिमिटेड
(पावरग्रिड की एक पूर्ण स्वामित्व वाली कंपनी)
पश्चिम क्षेत्रिय भार प्रेषण केन्द्र, मुम्बई
Power System Operation Corporation Ltd.
(A Wholly owned subsidiary company of POWERGRID)
Western Regional Load Despatch Centre, Mumbai



फैक्स संदेश
FAX MESSAGE

संदेश संख्या : भाप्रे / /
Msg.No. : LD/3/1790

दिनांक : / / 20
Date 16/3/2014

समय : : घण्टे
Date 7:41 hrs

प्रेषक / From : SCM, WRLDC, POSOCO, MUMBAI

प्रती / To :

- 1) SCM, NLDC / ERLDC / NRLDC / SRLDC / NERLDC
- 2) SCM, SLDC, CSPTCL / GETCO / MPPTCL / MSETCL / GOA / DD / DNH
- 3) SCM, NTPC / NPC-TAPS-KAPS / SSP / NSPCL / RGPPL
- 4) SCM, JPL / LANCO

प्रतिलिपी / Copy To :

- 1) SCM, NLDC / ERLDC / NRLDC / SRLDC / NERLDC
- 2) SCM, SLDC, CSPTCL / GETCO / MPPTCL / MSETCL / GOA / DD / DNH
- 3) SCM, NTPC / NPC-TAPS-KAPS / SSP / NSPCL / RGPPL / JPL / LANCO
- 4) CEO-GM-AGM, POSOCO / M.S.-S.E.(O), WRPC

विषय :

Sub : Bus fault on Bableswar Bus-II on 16-03-2014

As intimated by SLDC, Kalwa, MSETCL at 16:39 hrs ^{16.03.14} the following feeders tripped on Bus fault at Bableswar on Bus-II (i)
400kV Bableswar-Padghe-II
400kV Bableswar-Dhule-II
400kV Bableswar-Bhusawal &c.
~~500kV~~ 400/220kV ICT-III was under S/D since 1100MVA Bus extension works (i)
No Load interruption took place (i) No critical loadings reported (i) supply extended to Bus-II through Bus coupler at 17:01 hrs (i) Rest of restoration ~~as~~ as given below:

Bableswar-Bhusawal &c : 17:06 hrs / 16-03-14
Bableswar-Padghe-II : 17:08 hrs / 16-03-14
Bableswar-Dhule-II : 17:15 hrs / 16-03-14
ICT-III remained out (i)
Detailed Report from SLDC, Kalwa awaited (i)

murali kishna

(पारी प्रभारी)
(Shift Charge Manager)

राष्ट्रहित में ऊर्जा बचाएँ।