



Power System Operation Corporation Limited
Western regional Load Despatch Centre
FLASH REPORT

MESSAGE NO- LD/08/1714

DATE:-24/08/2013

Incident: Trippings at Jejuri S/s

1. Date and Time: 24.08.13 and 05:56 HRS

2. Conditions

I. Frequency of NEW Grid

Event	Frequency	Time(hh:mm)
Pre incident	49.98	05:45
Post Incident	49.96	06:10

II. Demand Met

Sl.No	Area/Region	Demand Met(MW)
1	WR	27724
2	Gujarat	8783
3	Maharashtra	11224
4	Madhya Pradesh	4117
5	Chhattisgarh	2385
6	Goa	302
7	DD	265
8	DNH	617

2. Reason for Tripping: O/V and DPR relay operated at Jejuri S/S of MSEB.

3. Areas Affected By Disturbance

Load loss of approx. 400 MW as reported by MSEB .

4. Elements affected:

III. Major Lines effected

Sr No.	Name of the Element	Outage Time	Restoration time
1	400 KV JEJURI-LONIKHAND	05:56	STILL OUT
2	400 KV JEJURI-NEWKOYNA	05:56	STILL OUT
3	JEJURI ICT I (400/220)	05:56	STILL OUT
4	JEJURI ICT II (400/220)	05:56	STILL OUT
5	220KV JEJURI-JEJURI I	05:56	06:35
6	220KV JEJURI-JEJURI II	05:56	06:35
7	220KV JEJURI-PURSUNGI I	05:56	06:35
8	220KV JEJURI-PURSUNGI II	05:56	06:35
9	220KV JEJURI-PARVATI	05:56	06:35
10	220KV JEJURI-BARAMATI	05:56	06:35

5. Actions Taken: Attempts to charge 400KV JEJURI-NEWKOYNA lines made twice but not successful. Fault rectification work of 400 KV JEJURI-LONIKHAND line takenup. Further details are awaited from MSEB.

6. Current Status: All 220KV lines restored .

(Shift Charge Manager)



Power System Operation Corporation Limited

Western regional Load Despatch Centre

FLASH REPORT

To

S/I , NLDC

S/I,GEB,MPSEB,MSEB,CSEB,GOA,DD,DNH,NTPC,CGPL

MS, WRPC- For kind information.