

75

अनुक्रमांक :
Sr. No. 7452

पावर सिस्टम ऑपरेशन कारपोरेशन लिमिटेड
(पावरग्रिड की एक पूर्ण स्वामित्व वाली कंपनी)
पश्चिम क्षेत्रिय भार प्रेषण केन्द्र, मुम्बई
Power System Operation Corporation Ltd.
(A Wholly owned subsidiary company of POWERGRID)
Western Regional Load Despatch Centre, Mumbai



फैक्स संदेश
FAX MESSAGE

संदेश संख्या : भारे /
Msg.No : LD/1870

दिनांक : / /
Date 17/5/2014

समय : :
Date 12:55hrs

प्रेषक / From : SCM, WRDLC, POSOCO, MUMBAI
प्रती / To :

- 1) SCM, NLDC / ERLDC / NRLDC / SRLDC / NERLDC
- 2) SCM, SLDC, CSPTCL / GETCO / MPPTCL / MSETCL / GOA / DD / DNH
- 3) SCM, NTPC / NPC-TAPS-KAPS / SSP / NSPCL / RGPPL
- 4) SCM, JPL / LANCO

प्रतिलिपी / Copy To :

- 1) SCM, NLDC / ERLDC / NRLDC / SRLDC / NERLDC
- 2) SCM, SLDC, CSPTCL / GETCO / MPPTCL / MSETCL / GOA / DD / DNH
- 3) SCM, NTPC / NPC-TAPS-KAPS / SSP / NSPCL / RGPPL / JPL / LANCO
- 4) CEO-GM-AGM, POSOCO / M.S.-S.E.(O), WRPC

विषय :
Sub : Tripping of AKLTPS-units 1 & 2

It is understood that two units at AKLTPS (2x125mw) resulting in generation loss of about 205mw. Request to estimate the reason of tripping of units & Request to confirm the any further trippings took place at the same time. :-

To, S.C.F
WRDLC, Mumbai

13:28 hrs

→ The Cause of Tripping of AKLTPS 1 & 2 is B-phase Bus bar
C.T. Failure, at 11:55

→ 220KV Akrimota - Nathkunda Tripped at 11:55
→ 220KV Panandhra - Akrimota line is 'ON' hence NO
total black out.
→ lit up activity of AKLTPS-2 is going on.

lit up activity
SCF
SLDC, Gujarat

munzaliwisha
(पारी प्रपारी)
(Shift Charge Manager)

राष्ट्रिय में ऊर्जा बचाव।