



Power System Operation Corporation Limited
Western regional Load Despatch Centre
FLASH REPORT

Msg no:LD/ 04/799

Date: 08/04/14.

WRLDC/March - 2014

Incident: 08/04/14.

1. Date and Time: 08.04.2014 17:03 Hrs

2. Antecedent Conditions

I. Frequency of NEW Grid/SR Grid

Event	Frequency	Time(hh:mm)
Pre incident	50.07	17:03
Post Incident	50.03	17:04

II. Demand Met

Sl.No	Area/Region	Demand Met(MW)
1	WR	38254
2	Gujarat	11607
3	Maharashtra	16344
4	Madhya Pradesh	5844
5	Chhattisgarh	3055
6	Goa	388
7	DD	271
8	DNH	620
9	ESIL	370

2. Reason for Tripping: As intimated by MP, SLDC, LBB of 220 KV BINA (MPSEB) – BINA (PG) LINE operated at 220kV Bina MPPTCL Bus II at 17:03 Hrs.

3. Areas Affected By Disturbance: No Load/generation loss reported.

4. Elements affected:

Name of line	OUTAGE TIME(hrs)	RESTORATION TIME(hrs)
220 KV Bina– Bina PG S/C	17:03	Still out
220 KV Bina MP) – Bina MP) (220/132kV)I/C -II	17:03	17:44
220 KV Bina(MP)– Gwalior(MP) II	17:03	18:40
400/220 kV Bina MP ICT II	17:03	17:44
220 KV Bina(MP)– Sagar II	17:03	17:45
220 KV Bina(MP)– Guna II	17:03	17:54

5. Actions Taken: No critical loadings observed.

6. Current Status: It is understood that 220 kV Bina (MP)-Bina(POWERGRID) line did not trip at Bina(POWERGRID)end. It appears to be mal-operation, details awaited from MP.

(Shift Charge Manager)