

**POWERSYSTEM OPERATION CORPORATION LTD.**  
**A wholly owned subsidiary company of POWERGRID)**  
**WESTERN REGIONAL LOAD DESPATCH CENTRE**  
**MUMBAI.**



**FAX MESSAGE**

**No: LD/ 01/1576**

**Date: 13.01.15**

**Time:20:32 Hrs**

---

**FROM: SHIFT CHARGE MANAGER, WRLDC, MUMBAI.**

**TO : S/I NLDC, NEW DELHI**

**CC : S/I MSEB/SLDC GOA**

---

The following 220kv lines of Ponda sub station of GOA got tripped on 13.01.15 as per the details below:-

SL NO.	NAME OF ELEMENT	Tripping Time(in Hrs)	Restoration Time(in Hrs)	Remark
1	220 Kv Mapusa-Ponda-s/c	16:30		Tripped on Y-N fault conductor snapped Y ph @ Loc no. 40
2	220 Kv Amona-Ponda-s/c	16:30	16:50	Directional E/F relay
3	220KvKolhapur-Ponda-S/C	16:30	16:35	Directional E/F relay
4	220KvTillari-Ponda-S/C	16:30	18:10	Directional E/F relay

Due to tripping of above lines 220KV both bus got dead at Ponda sub station , Though GOA was well connected through SR grid. 140MW load loss reported by GOA interruption duration was about 5-20min.

As restoration process started immediately by 16:35 and restored fully at 16:50hrs /13.01.15.

Before tripping Goa was meeting a Demand of WR 285MW+SR 100MW. Further details are awaited by SLDC GOA.

This is for kind information please.

**S/I, WRLDC**