



protectionwrlde &lt;protectionwrlde@gmail.com&gt;

---

**BUS FAULT OCCURRENCE AT ISP S/S AT 02:21HR 18.05.16**

---

Wrlde Mumbai &lt;wrldeposoco@gmail.com&gt;

Wed, May 18, 2016 at 7:13 AM

To: [REDACTED]  
[REDACTED]  
[REDACTED]  
[REDACTED]

Sir,  
Due to R phase CVT blast of Bus - II at ISP and Bus bar protection of Bus - 1&2 operated at 02:21hr /18.05.16 and all emanating lines tripped. Generation loss of ISP total around 218MW(unit-2 & unit-7).  
All lines restored except ISP-Indore-I and ISP-Nagda as reported by MP SLDC.  
For kind information.

—  
पा.प्र. सं.(SCM)  
नियंत्रण कक्ष (Control Room)  
पश्चिम क्षेत्रीय भार प्रेषण केंद्र, मुंबई  
(Western Regional Load Despatch Centre, Mumbai)  
संपर्क (Contact) - 022-28203885, 28397634  
पन. कॉम(PUNCOM) - 500-112,113,114,115  
फैक्स (FAX) - 022-28202630,93  
पन. कॉम फैक्स(PUNCOM FAX) -500101

---

Information contained and transmitted by this email is confidential and proprietary to The Power System Operation Corporation Ltd. and is included for use only by the addressee. If you are not the intended recipient, you are notified that any dissemination or copying of this email or contents therein is strictly prohibited. If this message is not intended for you, then you are requested to delete this email immediately and notify the originator.

---

 **BUS FAULT OCCURENCE AT ISP SS.pdf**  
189K