

FLASH REPORT

CGLD/06/92

DATE 03/06/2016

Time: 07:50 Hrs

Incident: Tripping of 400/220 KV LINES & Generating units of CSEB.

1. Date and Time: 06/06/2016 – 02:07 HRS TO 03:20 HRS

2. Antecedent Conditions : CLEAR WEATHER

3. Reason for Tripping: UNDER INVESTIGATION.

4. Generation loss: NIL

5. Areas Affected By Disturbance: SURROUNDING AREA OF RAIPUR - BHILAI

6. Elements affected:

Sl.No	Name of Element	Tripping time	Restoration time	DEMAND REDUCE
1	160 MVA 220/132 KV XMER AT 220 KV S/S BHILAI	02:07 HRS	3:20 HRS	122 MW
2	125 MVA 220/132 KV XMER AT 220 KV S/S BHILAI	02:50 HRS	03:31 HRS	63 MW
3	160 MVA 220/132 KV XMER No. I & II & III AT 220 KV S/S URLA	03:05 HRS	03:20 HRS	320 MW

**Shift Incharge: SLDC:CSPTCL :
RAIPUR**