

Bus Fault on 220 kV Pophali Bus section 2 on 12 Nov 2016 at 17:05 Hrs

Fri 11/18/2016 12:27 PM

To: Shrikant Rajurkar <se1om@mahatransco.in>; MSETCL O&M <ceoandmmsetcl@gmail.com>; ee400kv karad <ee400kvkarad@gmail.com>; setcckarad@gmail.com <setcckarad@gmail.com>;

Cc: Srinivash <srinivas.chitturi@hotmail.com>; CE Maharashtra SLDC <cesldc@mahasldc.in>; Shrikant Rajurkar <ssrajurkar@gmail.com>;

Dear Sir/Mam,

On 12 Nov 2016 at 17:05 Hrs, Bu Fault occurred on 220 kV Pophali Bus section 2 causing tripping of following elements :

1. 220 kV Pophali - Pedambe II
2. 220 kV Pophali - New Koyna
3. 220 kV Bus Section II @ Pophali
4. 220 kV Pophali - Nerale

Kindly send the DR?EL along with the reports of the event.

आभार/Regards,
संरक्षण विभाग / Protection Dept
प० क्ष० भा० प्रे० के०/WRLDC
मुंबई /Mumbai

Information contained and transmitted by this email is confidential and proprietary to The Power System Operation Corporation Ltd. and is included for use only by the addressee. If you are not the intended recipient, you are notified that any dissemination or copying of this email or contents therein is strictly prohibited. If this message is not intended for you, then you are requested to delete this email immediately and notify the originator.