

Reg: Tripping of 400/220kV ICT-2(Jabalpur_PG) and 220kV Bus-2 at Sukha(MP)

WRLDC Control Room

Sent:03 March 2017 07:35

To: NLDC Control Room Gmail-2 [posoconldc@gmail.com]; Aditya Prasad Das; Chandan Kumar; Chitrankshi Ghangrekar; K Muralikrishna; Pradeep Kumar Sanodiya (psanodiya@posoco.in); Pushpa S; Vivek Pandey; WRLDC Reliability

Cc: V K Shrivastava; ms-wrpc [ms-wrpc@nic.in]; Abhimanyu Gartia

TO

S/I NLDC

Sir,

As informed by MPSLDC, B-Ph CT bursted on 220kV Side of 400/220kV ICT-2 (Jabalpur_PG) at Sukha(MP) at 21:17hrs and leading of Bus Bar protection operation and tripping of 220kV Bus-2.

The following feeders/elements connected to Bus-2 got tripped

S. NO	Element	Tripping time	Restoration time
1	400/220kV ICT-2	21:17hrs/02.03.17	Still out
2	220kV Sukha-Jabalpur-1	21:17hrs/02.03.17	23:14
3	220kV Sukha-Jabalpur-2	21:17hrs/02.03.17	23:48
4	220kV Sukha-Narsinghpur-2	21:17hrs/02.03.17	23:41
5	220kV Sukha-Panagar-2	21:17hrs/02.03.17	23:33
6	400/220 ICT-1 tripped on over current protection operation	21:17hrs/02.03.17	23:10
7	220kV Bus-2	21:17/02.03.17	02:15/03.03.17

No load loss reported by MPSLDC.

Detailed report awaited from MPSLDC.

For information please.

Regards

SCM/WRLDC