

पश्चिम क्षेत्र भार प्रेषण केन्द्र

एफ-3, सेन्ट्रल रोड, एम्.आई.डी.सी. एरिया, मरोल, अन्धेरी (पूर्व), मुंबई - 400 093.
दूरभाष : 022-28202691 • फैक्स : 022-28235434, 28202630 • ई-मेल : wrldc@posoco.in

WESTERN REGIONAL LOAD DESPATCH CENTRE

F-3, Central Road, MIDC Area, Marol, Andheri (East), Mumbai - 400 093.
Phone : 022-28202691 • Telefax : 28235434, 28202630 • E-mail : wrldc@posoco.in
CIN : U40105DL2009GOI188682

Ref: WRLDC/LOGISTICS-I/SCADA-SEM/GUJ/AUG03

दिनांक: 31.08.17

सेवा में,
S.E. (SCADA),
रा.भा.प्रे.के.,
GETCO-वडोदरा,
गुजरात-390021

विषय: दिनांक 14/08/17 से 20/08/17 तक SCADA vs SEM की तुलना

मा. महोदय/महोदया,

विश्वसनीय एवं संघटित विद्युत प्रणाली प्रचालन करने हेतु पोसोको की नीति अनुसार कुशलता एवं प्रभावशाली सेवाओं की गुणवत्ता के लिए प.क्षे.भा.प्रे.के. ने दिनांक 14/08/17 से 20/08/17 तक ISTS इंटरफेस पर SCADA vs SEM की वास्तविक ऊर्जा लेन-देन डेटा की तुलना की। तथा यह पाया गया

1. 66 के.व्ही. धोकडवा-दिउ प्रवाह का SCADA डेटा शून्य था जबकी मिटरों में कुछ अंक आ रहे थे, जिसके कारण केंद्र शासित प्रदेश दमन एवं दिउ के SCADA vs SEM आहरण डेटा में असंतुलन है।
आप से अनुरोध है की परिस्थिति का विश्लेषण करे एवं आवश्यक सुधारक कार्रवाई करे।

यह डेटा प.क्षे.भा.प्रे.के. की वैबसाइट पर निम्नलिखित स्थान पर मौजूद है। यह जानकारी केवल परिचालन का विश्लेषण करने एवं मापन व्यवस्था में भूल सुधार के लिए है एवं इसका इस्तेमाल व्यावसायिक उद्देश्य / सौदे के लिए न किया जाय।
<http://www.wrldc.org/ScadaVsSEM/>

आपका आभारी

शमित 31/8/17

समित कुमार साहा

मुख्य प्रबन्धक

प.क्षे.भा.प्रे.के.

पावर सिस्टम ऑपरेशन कारपोरेशन लिमिटेड
(भारत सरकार का उद्यम)
POWER SYSTEM OPERATION CORPORATION LIMITED
(A Government of India Enterprise)



पश्चिम क्षेत्र भार प्रेषण केन्द्र

एफ-3, सेन्ट्रल रोड, एम्.आई.डी.सी. एरिया, मरोल, अन्धेरी (पूर्व), मुंबई - 400 093.
दूरभाष : 022-28202691 • फैक्स : 022-28235434, 28202630 • ई-मेल : wrldc@posoco.in

WESTERN REGIONAL LOAD DESPATCH CENTRE

F-3, Central Road, MIDC Area, Marol, Andheri (East), Mumbai - 400 093.
Phone : 022-28202691 • Telefax : 28235434, 28202630 • E-mail : wrldc@posoco.in
CIN : U40105DL2009GOI188682

Ref: WRLDC/LOGISTICS-I/SCADA-SEM/GUJ/AUG-03

Date: 31.08.17

To,
S.E.(SCADA),
SLDC,
GETCO -Vadodara,
GUJRAT- 390021

Sub: Reporting of SCADA vs SEM comparison for 14/08/17 to 20/08/17

Dear Sir,

In line with the POSOCO policy towards enhancement of quality of services for reliable and integrated power system operation in an efficient and effective manner, WRLDC has carried out SCADA vs SEM comparison of Actual energy interchange at ISTS interface for the period 14/08/17 to 20/08/17. The following issues are noticed


1. The SCADA data of 66kv Dhokadava-Diu flow is zero whereas there is some reading in the meters during the said duration. Hence there is a mismatch in SCADA and SEM drawl data of union territory of Daman & Diu.

It is requested to analyse the same and take up corrective action where ever necessary.

The data has been updated at WRLDC web site at the following location. This information is given only for operational analysis and correction on measurement system and would not be used for any commercial purpose / transaction.

<http://www.wrldc.org/ScadaVsSEM/>

Yours sincerely



Samit Kumar Saha
Chief Manager
WRLDC